



Building Energy and Environmental Systems Laboratory (BEESL)
Department of Mechanical and Aerospace Engineering
College of Engineering and Computer Science
Syracuse University



Healthy People in Healthy Indoor Environments
INDOOR AIR
2022 June 12th to 16th
Kuopio FINLAND

Performance of in-duct bipolar ionization devices on pollutant removal and potential byproduct formation in indoor environments

*Jialei Shen*¹, Zhenlei Liu¹, Daniel Love², Mary Dekold², Beverly Guo¹, Michael J. Birnkrant², Peter J. McKinney², Bing Dong¹ and Jianshun Zhang^{1,3}

¹ Syracuse University

² Carrier Global Corporation

³ Nanjing University

IAQ and air cleaning technologies

Indoor air quality (IAQ) is vital to human health, comfort, productivity, and wellbeing.

Air cleaning technologies:


- Filtration
- Sorption
- Ionization
- Oxidation
- UVGI
- ...




Portable unit



Induct unit



(Zhang et al., 2022)



Transmission of SARS-CoV-2

In-duct needlepoint bipolar ionization technology

Air ions:



- attachment to particles → charge particles
- contact with a surface
- recombination with other ions
- reaction with gaseous molecules

Commercially available needlepoint bipolar ionization devices:


- Generation of positive and negative air ions
- Charging particles for removal
- Inactivation of pathogen-laden particles
- Low ionization voltage (< 12V) to minimize the release of ozone and other byproducts

Typical configurations of induct bipolar ionizers:


- Single-pair portable unit
- Multi-pair portable unit
- Multi-pair ionizing bar



Multi-pair portable unit



Multi-pair ionizing bar



(Airusfans, 2022)



Commercially available induct needlepoint bipolar ionizers

Operation conditions

Tested bipolar ionization configurations:


- Configuration A (Ionizer A): Ionizing bar (4 bars), 34 pairs of +/- poles → mounted on a MERV 8 filter
- Configuration B (Ionizer B): Multi-pair portable unit, 6 pairs of +/- poles

Tested duct (to simulate a realistic AHU):

- A blower system placed in the chamber (a metal box/duct with a controllable blower fan at the inlet)
- A MERV 8 filter installed at the outlet (with the I-A mounted at the upstream side)
- I-B installed 0.25m upstream of the filter
- $Q = 505 \text{ m}^3/\text{h}$ during the tests

Full-scale environmental chamber with real-scenario office settings:

- Full-scale stainless-steel chamber in BEESL
- A full-scale single office built inside the chamber (3.5 × 3.0 × 2.7 m)
- Carpet, painted gypsum wallboard, table, partitions, heated manikin with soiled T-shirt
- Airflow rates: airtightness 0.01 ACH; low airflow $Q = 24.0 \text{ m}^3/\text{h}$ (minimal value by ASHRAE), high airflow $Q = 55.6 \text{ m}^3/\text{h}$
- Two mixing fans



Operation conditions

Particle injection:


- 8-jets nebulizer
- Purified clean air + salt solution
- Nominal injection airflow rate = 18 L/min
- Maintaining the steady-state PM_{2.5} below 100 – 200 $\mu\text{g}/\text{m}^3$ (close to the worst-case indoor concentration)

VOC (formaldehyde and toluene) injection:

- Dynacalibrator (VICI Metronics, Inc.)
- Formaldehyde and toluene permeation tubes used
- Target background level of 39.3 $\mu\text{g}/\text{m}^3$ for HCHO and 189.6 $\mu\text{g}/\text{m}^3$ for toluene

Heated manikin with soiled T-shirt (skin oil):

- A freshly cleaned T-shirt worn by a volunteer overnight prior the test day
- Manikin maintained at 33.9 degC
- Summer clothes (T-shirt + long trousers), 0.43 clo



Measurements

Monitors:

- Particles: APS,
- Ozone: 2B Tech Ozone monitor,
- VOCs: DNPH and Sorbent samples (HPLC and GCMS), PTRMS for background VOC level (w/ injection)
- CO₂: Gas Monitor and HOBO CO₂ logger
- Negative ion: Air ion counter

Sampling location:

Exhaust of the room (return air)

Procedure

Decay (“pull-down”) tests

Constant-source tests


Test method	Test ID	Test condition	Airflow condition	Injected pollutants	Test date
Decay test	Test 1	Natural decay	Infiltration ^a	Particles	Dec 1 st , 2021
	Test 2	Blower w/ MERV 8 filter	Infiltration	Particles	Nov 29 th , 2021
	Test 3	Ionizer A & filter	Infiltration	Particles	Nov 28 th , 2021
	Test 4	Ionizer B & filter	Infiltration	Particles	Nov 30 th , 2021
	Test 5	Ionizer B (w/t filter)	Infiltration	Particles	Dec 10 th , 2021
Constant-source test	Test 6	Ionizer A & filter	Low airflow ^b	Particles	Oct 28 th , 2021
	Test 7	Ionizer A & filter	Low airflow	Particles	Nov 24 th , 2021
	Test 8	Ionizer A & filter	High airflow ^c	Particles	Feb 14 th , 2022
	Test 9	Ionizer A & filter	High airflow	Particles	Feb 14 th , 2022
	Test 10	Ionizer A & filter	Low airflow	VOCs	Nov 23 rd , 2021

^a Infiltration: Environmental system was fully closed. There was only natural infiltration existing in the room, $\lambda_{inf} = 0.01\text{h}^{-1}$ (0.3 m³/h).


^b Low airflow: $Q = 24.0\text{ m}^3/\text{h}$.

^c High airflow: $Q = 55.6\text{ m}^3/\text{h}$.

Decay tests



Constant-source tests



Data analysis

Single-zone model

$$\lambda C_{in} = \lambda C_{out} - k_{dep} C_{in} + \frac{E}{V}$$

Decay tests

$$C_t = C_0 \cdot e^{-\lambda t}$$

$$\lambda = k_n + k_{AC} = (\lambda_{inf} + k_{dep}) + k_{filter} + k_{ionizer}$$

$$\lambda = \lambda_{inf} + \lambda_Q = \lambda_{inf} + \frac{Q}{V}$$

Clean air delivery rate (CADR) and single-pass removal efficiency (SPRE)


$$CADR = k_{AC} \cdot V$$

$$CADR = (Q + k_{dep} \cdot V) \cdot \left(\frac{C_1}{C_2} - 1 \right)$$

$$SPRE = \frac{CADR}{Q_{AC}}$$

Particle removal performance

Decay tests



Tests	Test 1	Test 2	Test 3	Test 4	Test 5
Test conditions	Natural decay	Filter (MERV 8)	I-A + filter	I-B + filter	I-B (w/t filter)
Natural decay rate ^a [h^{-1}]	0.22	0.25	0.24	0.25	0.20
Removal rate [h^{-1}]	/	0.54 0.29 (w/t decay)	1.82 1.58 (w/t decay)	1.59 1.34 (w/t decay)	0.87 0.67 (w/t decay)
CADR _{PM} [m^3/h]	/	15.7 8.5 (w/t decay)	53.0 46.0 (w/t decay)	46.3 38.9 (w/t decay)	25.3 19.4 (w/t decay)
SPRE _{PM} [%]	/	3.1 1.7 (w/t decay)	10.5 9.1 (w/t decay)	9.2 7.7 (w/t decay)	5.0 3.8 (w/t decay)

^a Natural decay rate (k_n): the combined effect of infiltration (λ_{inf}) and particle natural deposition (k_{dep}).


Airtightness: ACH = 0.01 /h

The combined use of ionizers (A and B) and MERV 8 filter showed an absolute increase on SPRE_{PM} by about 6-7.4%

The ionizer B alone (i.e., without the MERV 8 filter) provided very limited particle removal efficiency (3.8%).

Particle removal performance

Constant-source tests



Test	Q [m ³ /h]	k _{dep} ·V ^a [m ³ /h]	Average total particle number level in each state [# / cm ³]			CADR _{PM} ^b [m ³ /h]			SPRE _{PM} ^b [%]		
			Bkg	Blower on (w/ filter)	Ionizer A on	MERV 8 filter	Ionizer A & filter	Ionizer A ^c 8 filter	MERV 8 filter	Ionizer A & filter	Ionizer A
6	24.0	6.1	/	521.4	159.1	/	/	68.5	/	/	13.6
7	24.0	6.1	/	500.7	251.7	/	/	29.8	/	/	5.9
8	55.6	6.1	215.5	199.7	124.5	4.9	45.1	37.3	1.0	8.9	7.4
9	55.6	6.1	217.3	191.6	136.6	8.3	36.5	24.8	1.6	7.2	4.9
8 ^d	55.6	6.1	/	/	/	/	52.6 ^e	/	/	10.4 ^e	/

^a Assuming a constant particle deposition rate $k_{dep} = 0.21 \text{ h}^{-1}$. The estimated CADR_{PM} and SPRE_{PM} for the scenario with ionizer A and filter, and the scenario with ionizer A individually, may be underestimated as the actual particle deposition rate was likely higher when the ionizer was working.

^b Particle removal due to natural deposition were ruled out.

^c The CADR of ionizer was calculated through Eq. (6), instead of subtracting the CADR of filter from the CADR of ionizer and filter.



^d A decay test was performed along with the constant-source test of Test 8. The overall decay rate estimated from the exponential regression was 3.86 h^{-1} (including natural deposition and dilution by fresh air supplied by the control system Q).

^e Excluding natural deposition and dilution by fresh air supply.

	Filter	Filter + I-A	→ Individual I-A
SPRE _{PM}	1.0 – 1.6%	7.2 – 10.4%	→ 4.9 – 13.6%

Particle removal performance

Particle size distribution



Configurations	Test	Size-specific average SPRE _{PM} [%]	
		0.5-1.0 µm	1.0-2.0 µm
MERV 8 filter	Test 2	1.9	4.1
	Test 8	0.8	2.6
	Test 9	1.6	2.9
	Mean±SD	1.4±0.6	3.2±0.8
Ionizer A/B + filter	Test 3	9.2	12.2
	Test 4	7.7	10.3
	Test 8	8.8	10.0
	Test 9	7.0	9.3
	Mean±SD	8.2±1.0	10.5±1.2

MERV 8 filter removed larger particle more efficiently

I-A and I-B alone removed smaller particles more readily

When integrated with the filter, ionization can improve the particle efficiency considerably for greater particles.

→ It is preferred to apply ionizers in the air duct integrated with the filter rather than using the ionizer independently

Byproduct formation – Air ions

Adverse effects on cardiovascular health were observed when people were exposed to 13×10^3 #/cm³ and 60×10^3 #/cm³ level of airborne negative ions in literature


→ Maintaining the indoor air ion at a relatively healthy level

I-A released negative ions to indoor air at a rate between 5.1×10^{11} and 9.8×10^{11} #/h (with filter)

I-B generated negative ions at a rate of 5.4×10^{13} #/h (w/t filter) and 1.3×10^{12} #/h (w/ filter), indicating a significant reduction of 97.6% through the filter

→ Filter (at downstream) can remove most air ions (almost 100% drop of air ions through MERV 11-12 filters in literature)

Negative ions were decomposed very quickly in the fully mixed space




Byproduct formation – Ozone

Slight ozone increase/generation during decay tests (ACH = 0.01 /h)

- I-A + filter: 0.39 mg/h
- I-B + filter: 0.63 mg/h
- I-B: 0.92 mg/h

No ozone generation detected during constant-source tests (realistic scenarios)



VOC removal and formation

The variation of VOC concentrations before/after using ionizers were within the background fluctuation (PTRMS data)

No VOC removal or formation were detected

Compounds	Formula	VOC concentration at different test conditions [µg/m³]							% change after using ionizer	Relative SD of reference bkg VOC levels ^c [%]
		Bkg	Blower on (with filter)			Ionizer A on				
			Set 1 ^b		Mean	Set 1		Mean		
			t = 0h	t = 9h		t = 12h	/			
Formaldehyde ^a	CH2O	20.6	18.4	19.8	19.1	19.5	22.1	20.8	+8.9%	4.3%
Acetaldehyde	C2H4O	6.6	5.2	5.0	5.1	4.9	4.3	4.6	-9.8%	12.5%
Acetone	C3H6O	9.1	9.0	9.4	9.2	10.1	10.4	10.3	+12.0%	10.5%
Benzene	C6H6	1.8	1.8	1.7	1.8	1.8	1.8	1.8	0.0%	66.7%
Toluene ^a	C7H8	138.7	141.5	139.9	140.7	144.1	150.3	147.2	+4.6%	4.0%
Cyclotrisiloxane, hexamethyl-	C6H18O3Si3	3.8	3.1	3.2	3.2	3.2	3.6	3.4	+6.2%	25.0%
Hexanal	C6H12O	2.5	2.3	2.3	2.3	2.4	2.7	2.6	+13.0%	6.0%
Ethylbenzene	C8H10	n.d.	n.d.	n.d.	n.d.	1.1	1.2	1.2	+	n.d.
Cyclotetrasiloxane, octamethyl-	C8H24O4Si4	2.8	1.6	1.6	1.6	1.6	1.8	1.7	+6.2%	38.8%
Benzaldehyde	C7H6O	2.2	1.8	2.0	1.9	2.3	2.2	2.2	+15.8%	207.7%
2(5H)-Furanone, 3-methyl-	C5H6O2	2.2	1.8	n.d.	1.8	n.d.	n.d.	n.d.	-	n.d.
Phenol	C6H6O	1.0	0.8	0.9	0.9	0.9	0.9	0.9	0.0%	12.5%
Cyclopentasiloxane, decamethyl-	C10H30O5Si5	1.4	1.1	1.4	1.3	1.4	2.1	1.7	+30.8%	18.8%
Acetophenone	C8H8O	2.5	1.5	1.0	1.2	1.0	1.1	1.1	-8.3%	32.0%
Nonanal	C9H18O	1.3	1.1	1.1	1.1	1.5	1.8	1.7	+54.5%	47.8%
Naphthalene	C10H8	2.2	2.0	1.7	1.9	1.5	1.9	1.7	-10.5%	n.d.
Propanoic acid, 2-methyl-, 1-(1,1-dimethylethyl)-2-methyl-1,3-propanediyl ester	C16H30O4	4.1	5.3	5.6	5.4	5.7	5.4	5.6	+3.7%	27.6%
TVOC	/	202.8	198.3	196.6	198.5	203.0	213.6	208.5	+5.0%	/

^a Injected compounds.

^b Two duplicated samples were collected for each sampling set. The average of two duplicated samples was calculated and presented in the table.

^c From Table 6.

Electric power (measured by a power line meter)

I-A: 0.4 W

I-B: 1.0 W

Typical power of portable air cleaners: 56 W (median)

→ Power / $CADR_{PM}$:

I-A: 0.006 – 0.016 W/(m³/h)

I-B: 0.033 – 0.052 W/(m³/h)

Typical portable air cleaners: 0.15 W/(m³/h)

→ Moderate particle removal efficiency, no significant byproduct formation, low energy use, (price of ionizer?)

1. With the application of ionizer, the equivalent $SPRE_{PM}$ increased from 1.0-1.7% for the regular MERV 8 filter to 7.2-10.4% for the combined ionizer A/B and filter assembly
2. Most ions generated by the ionizer were trapped/captured by the filter
3. No significant ozone and VOC generated under realistic scenarios
4. No VOC removal
5. Cost and efficacy: Moderate particle removal efficiency, but low energy use

Acknowledgement



Syracuse University
Carrier Global Corporation





Thanks!

Jialei Shen
jshen20@syr.edu